

MARCH PUMPS

1819 PICKWICK AVE., GLENVIEW, IL 60026-1306, U.S.A PHONE: (847) 729-5300 - FAX: (847) 729-7062 WWW.MARCHPUMP.COM

809-HS 12 & 24 VDC HOT WATER PUMPS

DESCRIPTION:

March 809 Series hot water booster centrifugal magnetic drive pumps are built to handle liquid transfer in heating and cooling operations. Contact the factory for application assistance.


INSTALLATION:

Pumps are not self-priming, lack a suction lift, and thus require a flooded suction. Pumps cannot be run dry. The 809 Series pumps should be installed with the pump housing arrow pointing in the direction of flow within the system. If the arrow indicating flow is not in the direction required, remove the housing screws holding the housing to the motor bracket and rotate the housing assembly as required. Replace the screws and tighten. The pump is composed of a wet end assembly which can be separated by unscrewing the housing screws. The pump will then separate into 2 parts. The liquid will be contained within the wet end assembly unless the screws on the rear housing are loosened.

GENERAL SAFETY INFORMATION:

Follow all local electrical and safety codes, and the Occupational Safety and Health Act (OSHA). Make certain that the power source conforms to the requirements of your equipment. Always disconnect power source before performing any work on or near the electric motor. Caution must be exercised to relieve any pressure in the system and in draining hot water from the pump or the system. March cannot recommend the 809 Series out of bronze where the liquid is used for human consumption per California Law due to the presence of lead.

DISASSEMBLY & REASSEMBLY: The motor can be removed from the wet end assembly without draining the liquid from the system. To do so remove four housing screws and slide the motor assembly away. If parts inside the wet end assembly must be removed, isolate the pump or drain the system. When the system is drained and cool, remove the four screws from the rear of the housing. The rear housing can now be removed. Remaining pump parts can be removed. Replace any worn or damaged parts. Replace the "O" ring anytime the rear housing is removed.



SPECIFICATIONS								
	809-BR-HS	809-PL-HS	809-SS-HS	809-BR-HS-C	809-PL	HS-C	809-SS-HS-C	
Model Abbreviations	BR: Bronze	PL: Polysulfone	SS: Stainless	BR: Bronze		/sulfone	SS: Stainless	
	Inline Inlet, HS: High Speed			C: Center Inlet, HS: High Speed				
Max Flow	- 31			8 gpm - 30.2 lpm				
Max Head				15.5 ft / 6.7 psi - 4.7 m				
Inlet				3/4" MPT 3/8" FPT & 3/4" MPT 3/4" MPT				
Outlet				1/2" MPT				
Max Internal Pressure		50 psi / 3.4 bar	150 psi / 10 bar	150 psi / 10 bar	50 psi / 3.4 bar		150 psi / 10 bar	
Max Liquid Temperature				250°F / 121°C				
Overall Pump Inches	4.87 x 3.31 x 6.94	4.88 x 3.38 x 6.94	4.87 x 3.31 x 6.94	4.69 x 4.50 x 8.33	4.56 x 4.50 x 7.83		4.69 x 4.50 x 8.27	
Size (H x W x L) cm	17.6 x 8.4 x 12.3	17.6 x 8.5 x 12.3	17.6 x 8.4 x 12.3	11.9 x 11.4 x 21.1	11.5 x 11.4 x 19.8		11.9 x 11.4 x 21.0	
Packed Weight	5.5 lbs / 2.5kg	4.5 lbs / 2 kg	5.5 lbs / 2.5kg	5.5 lbs / 2.5kg	4.5 lbs / 2 kg		5.5 lbs / 2.5kg	
Motor Type	DC Brush Motor 12V DC Brus		Brush Motor 24V	DC Brush Motor 12V		DC B	DC Brush Motor 24V	
Watts - Amps	43 - 3.5	5 43 - 1.8		43 - 3.5 43 - 1.8				
Hp / Kw - Rpm	1/25 / 0.029 - 3650			1/25 / 0.029 - 3650				
Electrical Connection	Leads (Red lea	Leads (Red lead is positive & Blue lead is negative)						
All specifications & data are based on pumping water & are intended as a guideline only. Specifications may vary with different motors.								

LIMITED WARRANTY: March pumps are guaranteed only against defects in workmanship or materials for a period of one year from date of manufacture

pumping water. For the complete warranty and to register online go to www.marchpump.com/warranty-registration

